



**LOCATION 2**  
 SOUTH RD POLE 31/19M1  
 INSTALL  
 50'2 POLE SET DEEP  
 8' TAN XARM DTR10.421.1A  
 "N" BRACKET  
 144 KVA 100A VOLT/VAR WITH CONTROL & BYPASS SW  
 DTR20.381.1C  
 EQUIPMENT & CONTROL GROUNDING DTR16.311.1A  
 2 - PRIMARY SHOES  
 2 - WEDGE CONNECTORS  
 SUSPENSION INSULATOR & BYPASS SW TO BE INSTALLED ON  
 SOURCE SIDE  
 STENCIL POLE  
 TRANSFER PRIMARY & "N"

**LOCATION 3**  
 SOUTH RD POLE 31/19M VZ13 1/2  
 REMOVE  
 "N" BRACKET  
 POLE TOP, CUT POLE TOP  
 POLE  
 INSTALL  
 50'2 POLE SET DEEP  
 8' TAN XARM DTR10.421.1A  
 "N" BRACKET  
 144 KVA 100A VOLT/VAR WITH CONTROL & BYPASS SW  
 DTR20.381.1C  
 EQUIPMENT & CONTROL GROUNDING DTR 16.311.1A  
 2 - PRIMARY SHOES  
 2 - WEDGE CONNECTORS  
 SUSPENSION INSULATOR & BYPASS SW TO BE INSTALLED  
 ON SOURCE SIDE  
 STENCIL POLE  
 TRANSFER PRIMARY & "N"

**LOCATION 1**  
 SOUTH RD POLE 31/20 VZ 13  
 REMOVE  
 3 - LAs & BRACKETS  
 "N" BRACKET  
 GROUNDING  
 POLE TOP, CUT POLE TOP  
 POLE  
 INSTALL  
 50'2 POLE SET DEEP  
 8' TAN XARM DTR10.421.1A  
 "N" BRACKET  
 144 KVA 100A VOLT/VAR WITH CONTROL & BYPASS SW  
 DTR20.381.1C  
 EQUIPMENT & CONTROL GROUNDING DTR16.311.1A  
 2 - PRIMARY SHOES  
 2 - WEDGE CONNECTORS  
 SUSPENSION INSULATOR & BYPASS SW TO BE  
 INSTALLED ON SOURCE SIDE  
 STENCIL POLE  
 TRANSFER PRIMARY & "N"

**PROPRIETARY INFORMATION:**  
 THE INFORMATION ON THIS MAP SHALL BE CONSIDERED PROPRIETARY  
 TO EVERSOURCE AND THE USER (WHICH SHALL BE DEFINED AS ANY  
 PERSON OR ENTITY WHO HAS RECEIVED THE MAP THROUGH SALE,  
 PURCHASE, EXCHANGE, GIFT OR OTHERWISE) SHALL KEEP IT IN  
 CONFIDENCE AND SHALL NOT FURNISH OR DISCLOSE IT TO ANY THIRD  
 PARTY WITHOUT PRIOR WRITTEN PERMISSION OF EVERSOURCE  
 UTILITIES.



VVO VOLTAGE REGULATORS  
 SOUTH RD  
 WESTHAMPTON

DATE	CIRCUIT	VOLTAGE	MAXIMO WD	FIELD WD
08/13/21	15A3	23kV	6039664	80089729

SCALE: NTS DRAWN BY C. TROSDINO-LARAMY 413-250-0084